




GENERAL CERTIFICATE OF COMPLIANCE

DESCRIPTION: BIO FIRESHIELD™ FIRESTOPPING PRODUCTS
BIOTHERM™ 100/200SL SILICONE SEALANT
BIOSTOP® BF 150+ FIRESTOP SEALANT
BIOSTOP® 350i FIRESTOP SEALANT
BIOSTOP® 500+ SEALANT SEALANT
BIOSTOP® 700 SPRAYABLE MASTIC
BIOSTOP® 750 SPRAYABLE MASTIC
BIOSTOP® 800 SPRAYABLE MASTIC
BIOSTOP® COMPOSITE SHEET
BIOSTOP® FIRESTOP GASKET
BIOSTOP® FIRESTOP PILLOW
BIOSTOP® INTUMESCENT SLEEVE
BIOSTOP® JOINT STRIP
BIO FIRESHIELD™ LECTRA-STOP™
BIO FIRESHIELD™ PASS-THRU DEVICE
BIO K-10+™ FIRE RATED MORTAR
BIOSTOP® PIPE COLLAR
BIOSTOP® PUTTY STICK AND PUTTY PAD
BIOSTOP® WRAP STRIP

THESE PRODUCTS ARE TESTED ACCORDING TO ONE OR MORE OF THE FOLLOWING STANDARDS:


- U.L. 263 - FIRE TESTS OF BUILDING CONSTRUCTION AND MATERIALS
- U.L. 1479 - FIRE TESTS OF THROUGH-PENETRATION FIRESTOPS
- U.L. 2079 - TESTS FOR FIRE RESISTANCE OF BUILDING JOINT SYSTEMS
- ASTM E-814 - FIRE TESTS OF THROUGH-PENETRATION FIRESTOPS
- ASTM E-84 (UL 723) - SURFACE BURNING CHARACTERISTICS OF BUILDING MATERIALS
- IEEE- 383 - FLAME PROPAGATION TEST
- ASTM E2307 - TEST METHOD FOR DETERMINING FIRE RESISTANCE OF PERIMETER FIRE BARRIER SYSTEMS

ALL PRODUCTS CONTAIN NO ASBESTOS OR PCB'S AND ARE CONSIDERED V.O.C. COMPLIANT.


Eva Ackerman, Ph.D.
Vice President, Research and Technology


Terry Gossett
Technical Services

SUBSCRIBED AND SWORN TO BEFORE ME THIS 13th DAY OF OCTOBER 2011.


MELISSA SCHOENBERG
NOTARY IN AND FOR THE STATE OF TEXAS
COUNTY OF HARRIS
MY COMMISSION EXPIRES OCTOBER 25, 2015

